

## U. S. Steel Minntac

Monitoring Well Data for which there are no eDMR forms<sup>1</sup>

All samples collected: 10/5/2016

Parameter	Units	Monitoring Well Designation		
		MW-12	MW-13	MW-14
Groundwater Elevation	ft, msl	1454.4	1465	1472.7
Specific Conductance	uS/cm	1531	1036	662
Temperature	°C	10.0	10.2	10.9
pH	S.U.	6.6	6.4	7.2
Total Dissolved Solids	mg/L	1060	630	422
Sulfate, Total	mg/L	461	293	28.3
Chloride, Total	mg/L	106	36.2	3.1

<sup>1</sup>Included with the October 2016 eDMRs for NPDES/SDS Permit No. MN0057207 as a **Supplemental Report General**